

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

For 1 September 2025 to 30 September 2025

	Ardmore WTP Treated A mg/L	Ardmore WTP Treated B1 mg/L	Huia WTP Treated mg/L	Papakura WTP Treated mg/L	Pukekohe WTP Treated mg/L	Waikato WTP Treated mg/L	Waitakare WTP Treated mg/L
1 September 2025			0.82	0.88			
2 September 2025					0.85		0.86
3 September 2025	0.84	0.88				0.85	
8 September 2025			0.84	0.85			
9 September 2025							0.86
10 September 2025	0.77	0.78			0.87	0.81	
15 September 2025			0.81	0.9			
16 September 2025						0.67	0.88
18 September 2025	0.79	0.83			0.83		
22 September 2025			0.03*	0.86			
23 September 2025							0.76
24 September 2025	0.89	0.9				0.82	
26 September 2025					0.83		
29 September 2025			0.02*	0.89			
30 September 2025					0.86		0.73

Metropolitan Water Treatment Plants - Treated Water Fluoride Concentration

Note

Fluoride is added to Auckland's metropolitan water supply at the requirement of the Health (Fluoridation of Drinking Water) Act 2021.

The Ministry of Health recommends that the fluoride content in New Zealand drinking water should be maintained in the range of 0.7 to 1.0mg/L for oral health reasons. Testing is carried out by an accredited laboratory using the Ion Selective Electrode method as per New Zealand's Drinking Water Standards.

* Huia WTP fluoride dosing was turned off due to installing a replacement dose tank between the 17th of September and the evening of the 29th of September.